

**August 8th City Water Update**  
**Recent drinking water test results on Well #7**

A drinking water sample was collected from Well #7 on Tuesday, August 5th.

- Laboratory test results received on Weds., August 6th, showed Total Coliform present. E.Coli was not present.

The same day the results were received (Weds., August 6th)

- Well #7 was chlorinated and flushed, and
- Another water sample was collected.

On Thursday, August 7th

- A second water sample was collected from Well #7
- Both Weds and Thurs samples were delivered to the laboratory for Total Coliform and E. Coli testing.

Today, August 8th

- The City Water Department received the water test results at approximately 3:00 p.m.
- NO Total Chloroform or E. Coli were present in either sample.
- Well #7 was then put back on line.

<b>City of Apalachicola Drinking Water Results from Well #7</b> <b>August 5-7, 2025</b>			
<b>Date Sampled</b>	<b>Results Received</b>	<b>Total Coliform Present?</b>	<b>E-Coli Present?</b>
Tues, Aug. 5th	Weds, Aug. 6th	Yes	No
Weds, Aug. 6th Thurs. Aug. 7th	Friday, Aug. 8th*	No	No
*Results received by the laboratory at approximately 3:00 p.m. on August 8th			

Next steps:

- The next water sample for Total Coliform and E.Coli testing will be collected at the beginning of next month (per FDEP regulations).
- Weekly summaries will continue.