

ADDENDUM NO. 1

Date: November 3, 2025

Project Title: City of Apalachicola Wastewater Collection System Improvements

Bid Opening Date/Time: November 19, 2025 at 2:00.

This Addendum is issued to modify, clarify, and become a part of the original Bid Documents for the above-referenced project.

TO ALL PROSPECTIVE BIDDERS:

This Addendum takes precedence over conflicting provisions in the original bid documents. Bidders should adjust their estimates and proposals accordingly

CHANGES TO SPECIFICATIONS Under Quality Assurance Section C:

Alternate Apalachicola Wastewater Collection System proposals will be accepted without the use of the Engineer. The City will be using an Engineer for bid recommendation and oversight of this project. Alternate Apalachicola Wastewater Collection System proposals will be due the same time as any other proposal.

The City has completed 60% of this project using Flo-Vac and any other system proposal would be responsible for the cost of the project already completed to make necessary changes, adjustments, replacement parts to ensure the systems are completely interchangeable.

Alternate Vacuum Systems Proposal will need to price the cost of replacing 305 existing Flo-Vac Monitors.

BIDDER'S ACKNOWLEDGEMENT:

Bidders must acknowledge receipt of this Addendum by signing below and attaching it to their Bid Form. Failure to acknowledge all addenda may lead to bid disqualification.

COMPANY NAME: _____

SIGNATURE: _____

CONTACT PERSON: _____

DATE: _____